



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 176

Customer

Facility Name: Hyatt House- Bloomfield

Address: 5335 Baum Blvd.
Pittsburgh, Pa 15224

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/25/26

Time: 12:05 PM

Method: Grab

Sample Final Analysis

Date: 8/28/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/26/26 10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/26 10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/26 4:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/25/26 12:05 PM	JT	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/25/26 12:05 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/26 12:05 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor