



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-12**

**Lab# 221**

**Customer**

**Facility Name:** Masonic Village  
**Address:** 1000 Masonic Dr.  
Sewickley, PA 15143

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 8/24/26  
**Time:** 4:00 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/27/26  
**Time:** 11:00 AM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/25/26 10:45 AM     | AS      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/25/26 10:45 AM     | AS      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/24/26 5:55 PM      | AS      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 8/25/26 11:40 AM     | AS      | SM 9230C |
| Field Analysis        | Results  | Reporting limit | Date/Time            | Analyst | Method   |
| pH:                   | 7.4 SU   | 7.2 - 7.8 SU    | 8/24/26 4:00 PM      | MH      | DPD      |
| Chlorine:             | 5.0 mg/l | 1.0 - 5.0 mg/l  | 8/24/26 4:00 PM      | MH      | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 8/24/26 4:00 PM      | MH      | Visual   |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)