



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2558

Customer

Facility Name: Waldorf Tower
Address: 103 McKnight Circle
Pittsburgh, PA 15237

Sample Collection

Date: 8/26/26
Time: 12:26 PM
Method: Grab

Sample Final Analysis

Date: 8/29/26
Time: 11:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/26	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/26/26	12:26 PM	MM	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	8/26/26	12:26 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/26	12:26 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor