



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 483

Customer

Facility Name: YMCA - Schneider
Address: 2001 Ehrman Rd
Cranberry, PA 16066

Sample Collection

Date: 8/26/26
Time: 11:25 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Small Pool

Date: 8/29/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/26	4:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/26/26	11:25 AM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/26/26	11:25 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/26	11:25 AM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)