



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2646**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Stonecliffe*  
*Address:*      *1010 Stonecliffe Dr.*  
*Monroeville, PA 15146*

**Sample Collection**

*Date:*      8/26/26  
*Time:*      8:33 AM  
*Method:*      *Grab*

*Matrix:*      *Recreational Water*  
*Source Type:*      *Pool*

**Sample Final Analysis**

*Date:*      8/29/26  
*Time:*      10:00 AM  
*Analyst:*      AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/27/26              | 9:30 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/27/26              | 9:30 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/26/26              | 4:20 PM | AH      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|-----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU    | 7.2 - 7.8 SU    | 8/26/26   | 8:33 AM | JC      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 8/26/26   | 8:33 AM | JC      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 8/26/26   | 8:33 AM | JC      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor