



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2115

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Cloverleaf Estates
Address: 718 Cloverleaf Circle
Delmont, PA 15626

Date: 8/26/26
Time: 12:40 PM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 8/29/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/26	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/26	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/26	4:20 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/26/26	12:40 PM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/26/26	12:40 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/26	12:40 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor