



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2172**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Edgeworth Club*

*Date: 8/27/26*

*Time: 12:18 PM*

*Address: 511 East Drive*  
*Sewickley, PA 15143*

*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*

*Date: 8/30/26*

*Time: 5:00 PM*

*Source Type: Pool*

*Analyst: AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|---------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 8/27/26                     | 4:40 PM | SL             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 8/27/26                     | 4:40 PM | SL             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 8/27/26                     | 4:30 PM | SL             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|----------|----------------|---------------|
| pH:                   | 7.4 SU         | 7.2 - 7.8 SU           | 8/27/26          | 12:18 PM | SL             | DPD           |
| Chlorine:             | 2.0 mg/l       | 1.0 - 5.0 mg/l         | 8/27/26          | 12:18 PM | SL             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 8/27/26          | 12:18 PM | SL             | Visual        |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)