



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2173

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Edgeworth Club

Date: 8/27/26

Address: 511 East Drive
Sewickley, PA 15143

Time: 12:18 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/30/26

Source Type: Baby Pool

Time: 5:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/26	4:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/26	4:40 PM	SL	SM 9222B
Standard plate count:	50/ml	200/ml	8/27/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/27/26	12:18 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/27/26	12:18 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/27/26	12:18 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)