



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2332

Customer

Facility Name: Magee

Address: 745 Greenfield Ave.
Pittsburgh, PA 15217

Sample Collection

Date: 8/24/26
Time: 10:22 AM
Method: Grab

Matrix: Recreational Water

Source Type: Shallow End

Sample Final Analysis

Date: 8/27/26
Time: 10:00 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/25/26	9:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/25/26	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/24/26	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/24/26	10:22 AM	CC	DPD
Chlorine:	4.5 mg/l	1.0 - 5.0 mg/l	8/24/26	10:22 AM	CC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/24/26	10:22 AM	CC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)