



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Extra

Lab# 2805

Customer

Facility Name: A-Pex Newberry

Address: 1358 Oakridge Rd.
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/6/26

Time: 10:40 AM

Method: Grab

Sample Final Analysis

Date: 5/8/26

Time: 5:30 PM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/6/26	5:15 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/6/26	5:15 PM	AS	SM 9222B
Standard plate count:	150/ml	200/ml	5/6/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/6/26	10:40 AM	EB	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/6/26	10:40 AM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/6/26	10:40 AM	EB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)