



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

EOP-4

Lab# 2401

Customer

Facility Name: *Pgh Golf Club*
Address: *5280 Northumberland St.*
Pittsburgh, PA 15217

Sample Collection

Date: *5/19/26*
Time: *9:40 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *5/21/26*
Time: *10:30 AM*
Analyst: *AS*

Source Type: *Pool - Deep*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/20/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/20/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/19/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/19/26	9:40 AM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/19/26	9:40 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/19/26	9:40 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor