



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

EOP-3

Lab# 2802

Customer

Facility Name: Rolling Hills Aqua Park

Address: 110 WarriorsWay
McMurray, PA 15317

Matrix: Recreational Water

Source Type: Spray Pad

Sample Collection

Date: 5/21/26

Time: 12:52 PM

Method: Grab

Sample Final Analysis

Date: 5/22/26

Time: 2:30 PM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/21/26	2:20 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/21/26	2:20 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	5/21/26	2:20 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/21/26	12:52 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/21/26	12:52 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/21/26	12:52 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor