



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

APM

Lab ID No. 02-04041

Lab# 2608

Customer

Facility Name: Yards @ 3 Crossings

Address: 2645 Railroad St.
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/18/26

Time: 8:09 AM

Method: Grab

Sample Final Analysis

Date: 5/20/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/19/26 10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/19/26 10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	5/18/26 5:25 PM	AH	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/19/26 11:00 AM	JC	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/18/26 8:09 AM	JMH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	5/18/26 8:09 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/18/26 8:09 AM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor