Lab ID No. 02-04041
C-1

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab# ***041***

Customer

Facility Name: *Carnegie Mellon*

Address: *5000 Forbes Ave.*
Pittsburgh, PA 15213

Matrix: *Recreational Water*

Source Type: *Dive pool Shallow*

Sample Collection

Date: *3/11/26*
Time: 9:39 AM
Method: *Grab*

Sample Final Analysis

Date: *3/13/26*
Time: *5:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/11/26	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/11/26	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/11/26	4:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	3/11/26	9:39 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	3/11/26	9:39 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/11/26	9:39 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor