Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 168

Customer

Facility Name: *Home 2 Suites*

Address: *8630 Duncan Ave.*
Pittsburgh, PA 15237

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *3/25/26*
Time: 8:45 AM
Method: *Grab*

Sample Final Analysis

Date: *3/27/26*
Time: *4:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/25/26	3:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/25/26	3:30 PM	SL	SM 9222B
Standard plate count:	570/ml	200/ml	3/25/26	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	3/25/26	8:45 AM	VH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	3/25/26	8:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/25/26	8:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor