Lab ID No. 02-04041

Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

PPS

Lab# 045

Customer

Facility Name: *Carrick High School*

Address: *125 Parkfield St.*
Pittsburgh, PA 15210

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *3/9/26*
Time: 10:37 AM
Method: *Grab*

Sample Final Analysis

Date: *3/12/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	3/10/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	3/10/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	3/9/26	5:19 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	3/9/26	10:37 AM	MM	DPD
Chlorine:	1.5 mg/l	C	3/9/26	10:37 AM	MM	DPD
Turbidity:	1 NTU	A	3/9/26	10:37 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)