



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 2061**

**Customer**

Facility Name: *Brodhead North Associates*

Address: *3339 Brodhead Rd.*  
*Alliquippa, PA 15001*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *6/1/26*

Time: *12:02 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *6/3/26*

Time: *2:30 PM*

Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/2/26     | 2:00 PM   | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/2/26     | 2:00 PM   | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/1/26     | 7:00 PM   | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time | Analyst  | Method |        |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH:            | 7.2 SU   | 7.2 - 7.8 SU    | 6/1/26    | 12:02 PM | AMH    | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 6/1/26    | 12:02 PM | AMH    | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/1/26    | 12:02 PM | AMH    | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor