



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-15

Lab# 072

Customer

Facility Name: Courtyard by Marriott
Address: 150 Cranberry Woods Dr.
Cranberry, PA 16066

Sample Collection

Date: 6/2/26
Time: 1:20 PM
Method: Grab

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 6/4/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/26	11:00 AM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	6/2/26	6:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/26	1:20 PM	EG	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/2/26	1:20 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/26	1:20 PM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor