



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2153

Customer

Facility Name: *Dominion Homeowners*

Address: *1484 Zenith Court
Pittsburgh, PA 15241*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/1/26*

Time: *1:02 PM*

Method: *Grab*

Sample Final Analysis

Date: *6/3/26*

Time: *11:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/2/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/2/26	11:00 AM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	6/1/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/1/26	1:02 PM	JB	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/1/26	1:02 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/1/26	1:02 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor