



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2588

Customer

Facility Name: *Wilson Pool (Greentree Borough)*

Address: *825 Poplar Street
Pittsburgh, PA 15220*

Matrix: *Recreational Water*

Source Type: *Shallow End*

Sample Collection

Date: *6/1/26*

Time: *4:08 PM*

Method: *Grab*

Sample Final Analysis

Date: *6/3/26*

Time: *1:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/2/26	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/2/26	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/1/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/1/26	4:08 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/1/26	4:08 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/1/26	4:08 PM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)