



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 485

Customer

Facility Name: Hampton Inn Suites Mercer

Address: 4 Holiday Blvd
Mercer, PA 16137

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/1/26

Time: 8:35 AM

Method: Grab

Sample Final Analysis

Date: 6/3/26

Time: 2:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/2/26	2:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/2/26	2:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/1/26	7:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/1/26	8:35 AM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/1/26	8:35 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/1/26	8:35 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor