



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2445

Customer

Facility Name: Riverview Childrens

Address: 655 Sylvan Way
Verona, PA 15147

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/1/26

Time: 12:00 PM

Method: Grab

Sample Final Analysis

Date: 6/3/26

Time: 12:30 PM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/2/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/2/26	12:00 PM	AH	SM 9222B
Standard plate count:	170/ml	200/ml	6/1/26	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/1/26	12:00 PM	JL	DPD
Chlorine:	1.8 mg/l	1.0 - 5.0 mg/l	6/1/26	12:00 PM	JL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/1/26	12:00 PM	JL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor