



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 2791

Customer

Facility Name: Saltsburg Pool
Address: 230 10th St.
Saltsburg, PA 15681

Sample Collection

Date: 6/2/26
Time: 12:25 PM
Method: Grab

Sample Final Analysis

Date: 6/4/26
Time: 11:30 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Spray Pad

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/26	11:00 AM	AH	SM 9222B
Standard plate count:	10/ml	200/ml	6/2/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.2 SU	7.2 - 7.8 SU	6/2/26	12:25 PM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/2/26	12:25 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/26	12:25 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor