



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 414

Customer

Facility Name: *Townplace Suites Airport*

Address: *1006 Sutherland Dr.*
Pittsburgh, PA 15205

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *6/2/26*

Time: *10:45 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/4/26*

Time: *10:30 AM*

Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/26	10:00 AM	AH	SM 9222B
Standard plate count:	70/ml	200/ml	6/2/26	3:40 PM	AH	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/26	12:30 PM	SL	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/2/26	10:45 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/2/26	10:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/26	10:45 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)