



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-11**

**Lab# 2330**

**Customer**

**Facility Name:** Lot 24  
**Address:** 2404 Railroad St.  
Pittsburgh, PA 15222

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 6/1/26  
**Time:** 10:57 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/3/26  
**Time:** 1:30 PM  
**Analyst:** AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                       |          |          |                |    |          |
|-----------------------|----------|----------|----------------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 6/2/26 1:00 PM | AH | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 6/2/26 1:00 PM | AH | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml   | 6/1/26 6:00 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |                |    |          |
|---------------------|----------|----------|----------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 6/2/26 3:30 PM | AH | SM 9230C |
|---------------------|----------|----------|----------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|            |          |                |                 |    |        |
|------------|----------|----------------|-----------------|----|--------|
| pH:        | 7.6 SU   | 7.2 - 7.8 SU   | 6/1/26 10:57 AM | JH | DPD    |
| Chlorine:  | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/1/26 10:57 AM | JH | DPD    |
| Turbidity: | 1 NTU    | 1 - 2 NTU      | 6/1/26 10:57 AM | JH | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)