



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2608

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Yards @ 3 Crossings*

Address: *2645 Railroad St.*
 Pittsburgh, PA 15222

Sample Collection

Date: *5/25/26*
Time: *10:07 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Final Analysis

Date: *5/27/26*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	5/26/26	9:12 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/26/26	9:12 AM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	5/25/26	5:30 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	5/26/26	10:30 AM	AH	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

pH:	8.0 SU	7.2 - 7.8 SU	5/25/26	10:07 AM	JMH	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	5/25/26	10:07 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/25/26	10:07 AM	JMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)