



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM 2

Lab# 2113

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Clinton Lake

Date: 6/2/26

Address: 124 Clinton Dr.
Clinton, PA 15026

Time: 1:34 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/4/26

Source Type: Pool

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/26	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/2/26	1:34 PM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/2/26	1:34 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/26	1:34 PM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor