



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2374**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Facility Name:**      *Oak Hill Apts*  
**Address:**      *280 Burrows Street*  
*Pittsburgh, Pa 15213*

**Sample Collection**

**Date:**      *5/27/26*  
**Time:**      *12:30 PM*  
**Method:**      *Grab*

**Matrix:**      *Recreational Water*  
**Source Type:**      *Pool*

**Sample Final Analysis**

**Date:**      *5/29/26*  
**Time:**      *11:30 AM*  
**Analyst:**      *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 5/28/26                     | 11:00 AM | AH             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 5/28/26                     | 11:00 AM | AH             | SM 9222B      |
| Standard plate count:      | 570/ml         | 200/ml                 | 5/27/26                     | 7:10 PM  | SL             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|----------|----------------|---------------|
| pH:                   | 7.8 SU         | 7.2 - 7.8 SU           | 5/27/26          | 12:30 PM | AHV            | DPD           |
| Chlorine:             | 7.0 mg/l       | 1.0 - 5.0 mg/l         | 5/27/26          | 12:30 PM | AHV            | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 5/27/26          | 12:30 PM | AHV            | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor