



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-10**

**Lab# 2053**

**Customer**

**Facility Name:** *Bower Hill Swim Club*

**Address:** *1600 Bower Hill Road  
Pittsburgh, PA 15243*

**Matrix:** *Recreational Water*

**Source Type:** *Shallow End*

**Sample Collection**

**Date:** *6/22/26*

**Time:** *1:15 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *6/24/26*

**Time:** *10:30 AM*

**Analyst:** *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 6/23/26                     | 10:00 AM | AH             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 6/23/26                     | 10:00 AM | AH             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 6/22/26                     | 5:00 PM  | AS             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|---------|----------------|---------------|
| pH:                   | 7.4 SU         | 7.2 - 7.8 SU           | 6/22/26          | 1:15 PM | JB             | DPD           |
| Chlorine:             | 5.0 mg/l       | 1.0 - 5.0 mg/l         | 6/22/26          | 1:15 PM | JB             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 6/22/26          | 1:15 PM | JB             | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor