



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-17

Lab# 2769

Customer

Facility Name: Candlewood Suites

Address: 37 Holiday Blvd
Mercer, Pa 16137

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/25

Time: 3:50 PM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 12:00 AM

Analyst: AS


Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25	3:50 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/25	3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	3:50 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-17

Lab# 2769

Customer

Facility Name: Candlewood Suites

Address: 37 Holiday Blvd
Mercer, Pa 16137

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/25

Time: 3:50 PM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 12:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25	3:50 PM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/25	3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	3:50 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor