



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2223

Customer

Facility Name: Gateway Heights
Address: 2249 Ramsey Road
Monroeville, PA 15146

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/24/26
Time: 12:00 AM
Method: Grab

Sample Final Analysis

Date: 6/26/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/26	9:45 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/26	9:45 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/26	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/26	10:37 AM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/24/26	10:37 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/26	10:37 AM	SL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)