



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 116

Customer

Facility Name: Hampton Inn
Address: 1247 Smallman St.
Pittsburgh, PA 15222

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/22/26
Time: 9:55 AM
Method: Grab

Sample Final Analysis

Date: 6/24/26
Time: 12:00 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/22/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/22/26	9:55 AM	JMH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/22/26	9:55 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26	9:55 AM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor