



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2257

Customer

Facility Name: Highland Park Club
Address: 1001 N. Negley Ave.
Pittsburgh, PA 15206

Sample Collection

Date: 6/23/26
Time: 4:07 PM
Method: Grab

Sample Final Analysis

Date: 6/25/26
Time: 11:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26	10:55 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26	10:55 AM	AH	SM 9222B
Standard plate count:	50/ml	200/ml	6/23/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/26	4:07 PM	JT	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/26	4:07 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26	4:07 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor