



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 468

Customer

Facility Name: *Holiday Inn Express*

Address: *3936 Monroeville Blvd.
Monroeville, PA 15146*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/22/26*

Time: *2:09 PM*

Method: *Grab*

Sample Final Analysis

Date: *6/24/26*

Time: *1:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/22/26	6:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/22/26	2:09 PM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/22/26	2:09 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26	2:09 PM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor