



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 173

Customer

Facility Name: Hopewell Middle School

Address: 2354 Brodhead Rd
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/22/26

Time: 10:53 AM

Method: Grab

Sample Final Analysis

Date: 6/24/26

Time: 1:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26 12:30 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26 12:30 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/22/26 5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/22/26 10:53 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/22/26 10:53 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26 10:53 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)