



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 2324

Customer

Facility Name: Londonbury Homes

Address: 220 Downing Dr.
Moon, PA 15108

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 6/23/26

Time: 12:45 PM

Method: Grab

Sample Final Analysis

Date: 6/25/26

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26	8:55 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26	8:55 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/26	4:04 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/23/26	12:45 PM	VH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/26	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26	12:45 PM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)