



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-13

Lab# 2351

Customer

Facility Name: Mews - Town North
Address: Beech Court
Pittsburgh, PA 15237

Sample Collection

Date: 6/23/26
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 6/25/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26	9:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/26	4:04 PM	AH	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.7 SU	7.2 - 7.8 SU	6/23/26	12:30 PM	IS	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/26	12:30 PM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26	12:30 PM	IS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor