



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2401

Customer

Facility Name: *Pgh Golf Club*
Address: *5280 Northumberland St.*
Pittsburgh, PA 15217

Sample Collection

Date: *6/23/26*
Time: *2:34 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool - Deep*

Sample Final Analysis

Date: *6/25/26*
Time: *12:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26	11:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26	11:30 AM	MD	SM 9222B
Standard plate count:	5700/ml	200/ml	6/23/26	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/23/26	2:34 PM	JT	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/23/26	2:34 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26	2:34 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor