



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-11

Lab# 2424

Customer

Facility Name: Quail Run Condo Outdoor

Address: 199 Quail Run Rd.
Venetia, PA 15367

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/22/26

Time: 12:00 PM

Method: Grab

Sample Final Analysis

Date: 6/24/26

Time: 1:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26	1:00 PM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26	1:00 PM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	6/22/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/22/26	12:00 PM	AHV	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/22/26	12:00 PM	AHV	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26	12:00 PM	AHV	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor