



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-13**

**Lab# 2436**

**Customer**

**Facility Name:** Trellis North Fayette  
**Address:** 1500 Park Lane Drive  
Pittsburgh, PA 15275

**Matrix:** Recreational Water

**Source Type:** Spa

**Sample Collection**

**Date:** 6/23/26  
**Time:** 10:13 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/25/26  
**Time:** 9:30 AM  
**Analyst:** AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                       |          |          |         |         |    |          |
|-----------------------|----------|----------|---------|---------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 6/24/26 | 9:10 AM | MD | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 6/24/26 | 9:10 AM | MD | SM 9222B |
| Standard plate count: | 5700/ml  | 200/ml   | 6/23/26 | 4:04 PM | AH | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |         |         |    |          |
|---------------------|----------|----------|---------|---------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 6/24/26 | 2:25 PM | AH | SM 9230C |
|---------------------|----------|----------|---------|---------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|            |           |                |         |          |     |        |
|------------|-----------|----------------|---------|----------|-----|--------|
| pH:        | 8.0 SU    | 7.2 - 7.8 SU   | 6/23/26 | 10:13 AM | AMH | DPD    |
| Chlorine:  | 10.0 mg/l | 1.0 - 5.0 mg/l | 6/23/26 | 10:13 AM | AMH | DPD    |
| Turbidity: | 1 NTU     | 1 - 2 NTU      | 6/23/26 | 10:13 AM | AMH | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)