



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 266

Customer

Facility Name: *Residence Inn*
Address: *574 W. General Robinson St.*
Pittsburgh, PA 15212

Sample Collection

Date: *6/22/26*
Time: *10:59 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/24/26*
Time: *12:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/22/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/22/26	10:59 AM	JMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/22/26	10:59 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26	10:59 AM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor