



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 395

Customer

Facility Name: Seven Springs Resort
Address: 777 Waterwheel Dr.
Champion, PA 15622

Sample Collection

Date: 6/22/26
Time: 11:27 AM
Method: Grab

Sample Final Analysis

Date: 6/24/26
Time: 10:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Spa-Avalanche

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26	9:30 AM	MD	SM 9222G

Total coliforms:	0/100mls	2/100mls	6/23/26	9:30 AM	MD	SM 9222B
------------------	----------	----------	---------	---------	----	----------

Standard plate count:	0/ml	200/ml	6/22/26	4:00 PM	AH	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/23/26	1:30 PM	MD	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	6/22/26	11:27 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/22/26	11:27 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26	11:27 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)