



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-16**

**Lab# 2583**

**Customer**

**Facility Name:** Wildwood Golf Club  
**Address:** 2195 Sample Road  
Allison Park, PA 15101

**Sample Collection**

**Date:** 6/22/26  
**Time:** 3:10 PM  
**Method:** Grab

**Matrix:** Recreational Water  
**Source Type:** Shallow End

**Sample Final Analysis**

**Date:** 6/24/26  
**Time:** 12:30 PM  
**Analyst:** AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/23/26              | 12:00 PM | MD      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/23/26              | 12:00 PM | MD      | SM 9222B |
| Standard plate count: | 20/ml    | 200/ml          | 6/22/26              | 5:30 PM  | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 6/22/26   | 3:10 PM | MM      | DPD    |
| Chlorine:      | 0.5 mg/l | 1.0 - 5.0 mg/l  | 6/22/26   | 3:10 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/22/26   | 3:10 PM | MM      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor