



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-17**

**Lab# 355**

**Customer**

Facility Name: YMCA - Butler

Address: 339 North Washington St.  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 6/23/26

Time: 1:55 PM

Method: Grab

**Sample Final Analysis**

Date: 6/25/26

Time: 4:00 PM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |         |         |    |          |
|-------------------|--------|--------|---------|---------|----|----------|
| Escherichia Coli: | Absent | Absent | 6/24/26 | 3:35 PM | AH | SM 9222G |
|-------------------|--------|--------|---------|---------|----|----------|

|                  |          |          |         |         |    |          |
|------------------|----------|----------|---------|---------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 6/24/26 | 3:35 PM | AH | SM 9222B |
|------------------|----------|----------|---------|---------|----|----------|

|                       |      |        |         |         |    |          |
|-----------------------|------|--------|---------|---------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 6/23/26 | 6:20 PM | SL | SM 9215B |
|-----------------------|------|--------|---------|---------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |         |         |    |          |
|---------------------|----------|----------|---------|---------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 6/24/26 | 2:25 PM | AH | SM 9230C |
|---------------------|----------|----------|---------|---------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |         |         |    |     |
|-----|--------|--------------|---------|---------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/23/26 | 1:55 PM | MM | DPD |
|-----|--------|--------------|---------|---------|----|-----|

|           |          |                |         |         |    |     |
|-----------|----------|----------------|---------|---------|----|-----|
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 6/23/26 | 1:55 PM | MM | DPD |
|-----------|----------|----------------|---------|---------|----|-----|

|            |       |           |         |         |    |        |
|------------|-------|-----------|---------|---------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/23/26 | 1:55 PM | MM | Visual |
|------------|-------|-----------|---------|---------|----|--------|

**Sample comments**

*Andre Smith*

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)