



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2616

Customer

Facility Name: *Youghiogheny C.C.*
Address: *1901 Greenock Buena Vista Rd.*
McKeesport, PA 15135

Sample Collection

Date: *6/23/26*
Time: *9:50 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *6/25/26*
Time: *11:00 AM*
Analyst: *AS*

Source Type: *Deep End*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/23/26	9:50 AM	LL	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/23/26	9:50 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26	9:50 AM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor