



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 2767

Customer

Facility Name: Foundmore
Address: 300 Hillview Dr.
Ross Twp., PA 15237

Sample Collection

Date: 6/23/26
Time: 1:10 PM
Method: Grab

Sample Final Analysis

Date: 6/25/26
Time: 10:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/26 9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/26 9:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/26 4:04 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/23/26 1:10 PM	IS	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/23/26 1:10 PM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/26 1:10 PM	IS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor