



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2560

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Washington Gardens*

Address: *834 Washington Ave.*
Carnegie, PA 15106

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/22/26*

Time: *2:25 PM*

Method: *Grab*

Sample Final Analysis

Date: *6/24/26*

Time: *12:00 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26 11:30 AM	MD	SM 9222G

Total coliforms:	0/100mls	2/100mls	6/23/26 11:30 AM	MD	SM 9222B
------------------	----------	----------	-----------------------	----	----------

Standard plate count:	5/ml	200/ml	6/22/26 5:00 PM	AS	SM 9215B
-----------------------	------	--------	----------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	1/0/00 12:00 AM	0	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/22/26 2:25 PM	JB	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	6/22/26 2:25 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26 2:25 PM	JB	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)