



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2608

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Yards @ 3 Crossings*

Address: *2645 Railroad St.*
 Pittsburgh, PA 15222

Sample Collection

Date: *6/22/26*
Time: *8:24 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Final Analysis

Date: *6/24/26*
Time: *12:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26 12:00 PM	MD	SM 9222G

Total coliforms:	0/100mls	2/100mls	6/23/26 12:00 PM	MD	SM 9222B
Standard plate count:	100/ml	200/ml	6/22/26 5:30 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/23/26 1:30 PM	MD	SM 9230C

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/22/26 8:24 AM	JMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/22/26 8:24 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26 8:24 AM	JMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)