



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2081

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Carriage Park Apt.

Date: 6/23/26

Address: 300 Chatham Park Dr.
Pittsburgh, PA 15220

Time: 11:15 AM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 6/25/26

Time: 4:30 PM

Source Type: Deep End

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	6/24/26	4:10 PM	AH	SM 9222G
-------------------	--------	--------	---------	---------	----	----------

Total coliforms:	0/100mls	2/100mls	6/24/26	4:10 PM	AH	SM 9222B
------------------	----------	----------	---------	---------	----	----------

Standard plate count:	5/ml	200/ml	6/23/26	6:40 PM	SL	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.2 SU	7.2 - 7.8 SU	6/23/26	11:15 AM	JB	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/23/26	11:15 AM	JB	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	6/23/26	11:15 AM	JB	Visual
------------	-------	-----------	---------	----------	----	--------

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)