



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2653

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Edge 1909* *Date:* *6/22/26*
Address: *1909 Waterfront Place* *Time:* *9:16 AM*
Pittsburgh, PA 15225 *Method:* *Grab*

Sample Final Analysis

Matrix: *Recreational Water* *Date:* *6/24/26*
Source Type: *Pool* *Time:* *12:00 PM*
Analyst: *1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/23/26 11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/23/26 11:30 AM	AH	SM 9222B
Standard plate count:	5/ml	200/ml	6/22/26 5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/22/26 9:16 AM	JMH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/22/26 9:16 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/22/26 9:16 AM	JMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor